

No Significant Industrial User shall discharge or cause to be discharged wastewater that exceeds the following limits: Pollutant	Daily Maximum Limit ^(a)	Units
Arsenic	0.10	mg/L
Cadmium	0.06	mg/L
Chromium	21.21	mg/L
Copper	1.85	mg/L
Lead	0.66	mg/L
Mercury	0.002	mg/L
Molybdenum	0.27	mg/L
Nickel	1.24	mg/L
Selenium	0.25	mg/L
Silver	2.89	mg/L
Zinc	5.16	mg/L
Biochemical Oxygen Demand (BOD ₅) ^(b)	14,000	mg/l
Total Suspended Solid (TSS) ^(b)	9,000	Mg/l

With pH limit @ 5.0-11.0

The following limits shall apply to wastewaters that are discharged from the groundwater cleanup of petroleum or gasoline underground storage tanks or other remediation wastewaters containing these pollutants or where these pollutants are appropriate surrogates. It shall be unlawful for any Industrial User to discharge or cause to be discharged any waste or wastewater that exceeds the following limits, as applicable. Pollutant ^(c)	Daily Maximum Limit (mg/L)
Benzene ^(a)	0.050
BTEX ^(b)	0.750